



## ***DEPARTMENT OF PUBLIC HEALTH***

---

Fred Yanoski, MPH  
Director/Health Officer

Phone (989) 832-6380  
Fax (989) 832-6628

November 12, 2025

Heavens Elect  
3305 Ridgecrest Dr.  
Midland, MI 48642

RE: Filter First Water Sampling results

Dear Heavens Elect staff,

Please find the attached results for faucet fixtures sampled. All faucets sampled "NOT DETECTED" for Lead analysis. Should you have any questions about interpretation contact us (989) 832-6380.

Sincerely,

Robert Wolfe, R.S.  
Environmental Health Sanitarian  
[bwolfe@co.midland.mi.us](mailto:bwolfe@co.midland.mi.us)

Official Laboratory Report

Report To: MIDLAND COUNTY HEALTH DEPT  
220 WEST ELLSWORTH ST  
MIDLAND MI 48640

**Sample ID: LL92753**  
**Work Order: 51100255\_01**

System Name/Owner:	HEAVENS ELECT CHILDCARE CENTER	WSSN/Pool ID:	
Collection Address:	3305 RIDGECREST DRIVE,MIDLAND	Source:	Single Family Dwelling
Collected By:	BOB WOLFE, RS	Site Code:	FILTER FIRST TESTING
Township/Well#/Section:	CITY OF MIDLAND//	Collector:	Other
County:	Midland	Date Collected:	11/04/2025 08:55
Sample Point:	HE-SL-TL #2	Date Received:	11/05/2025 11:09
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper	Not detected	mg/L	0.05	11/06/2025	1.3	EPA 200.8	7440-50-8
Lead	Not detected	mg/L	0.001	11/06/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: MIDLAND COUNTY HEALTH DEPT  
220 WEST ELLSWORTH ST  
MIDLAND MI 48640

**Sample ID: LL92754**  
**Work Order: 51100255\_02**

System Name/Owner:	HEAVENS ELECT CHILDCARE CENTER	WSSN/Pool ID:	
Collection Address:	3305 RIDGECREST DRIVE,MIDLAND	Source:	Single Family Dwelling
Collected By:	BOB WOLFE, RS	Site Code:	FILTER FIRST TESTING
Township/Well#/Section:	CITY OF MIDLAND//	Collector:	Other
County:	Midland	Date Collected:	11/04/2025 09:12
Sample Point:	HE-LR-DF #4	Date Received:	11/05/2025 11:09
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper	0.20	mg/L	0.05	11/06/2025	1.3	EPA 200.8	7440-50-8
Lead	Not detected	mg/L	0.001	11/06/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: MIDLAND COUNTY HEALTH DEPT  
220 WEST ELLSWORTH ST  
MIDLAND MI 48640

**Sample ID: LL92756**  
**Work Order: 51100255\_04**

System Name/Owner:	HEAVENS ELECT CHILDCARE CENTER	WSSN/Pool ID:	
Collection Address:	3305 RIDGECREST DRIVE,MIDLAND	Source:	Single Family Dwelling
Collected By:	BOB WOLFE, RS	Site Code:	FILTER FIRST TESTING
Township/Well#/Section:	CITY OF MIDLAND//	Collector:	Other
County:	Midland	Date Collected:	11/04/2025 09:05
Sample Point:	HE-SA-CF #1	Date Received:	11/05/2025 11:09
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper	Not detected	mg/L	0.05	11/06/2025	1.3	EPA 200.8	7440-50-8
Lead	Not detected	mg/L	0.001	11/06/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: MIDLAND COUNTY HEALTH DEPT  
220 WEST ELLSWORTH ST  
MIDLAND MI 48640

**Sample ID:** LL92757  
**Work Order:** 51100255\_05

System Name/Owner:	HEAVENS ELECT CHILDCARE CENTER	WSSN/Pool ID:	
Collection Address:	3305 RIDGECREST DRIVE,MIDLAND	Source:	Single Family Dwelling
Collected By:	BOB WOLFE, RS	Site Code:	FILTER FIRST TESTING
Township/Well#/Section:	CITY OF MIDLAND//	Collector:	Other
County:	Midland	Date Collected:	11/04/2025 09:17
Sample Point:	HE-K3H-DF #5	Date Received:	11/05/2025 11:09
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper	0.27	mg/L	0.05	11/06/2025	1.3	EPA 200.8	7440-50-8
Lead	Not detected	mg/L	0.001	11/06/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: MIDLAND COUNTY HEALTH DEPT  
220 WEST ELLSWORTH ST  
MIDLAND MI 48640

**Sample ID: LL92758**  
**Work Order: 51100255\_06**

System Name/Owner:	HEAVENS ELECT CHILDCARE CENTER	WSSN/Pool ID:	
Collection Address:	3305 RIDGECREST DRIVE,MIDLAND	Source:	Single Family Dwelling
Collected By:	BOB WOLFE, RS	Site Code:	FILTER FIRST TESTING
Township/Well#/Section:	CITY OF MIDLAND//	Collector:	Other
County:	Midland	Date Collected:	11/04/2025 09:24
Sample Point:	HE-IR1-CF #6	Date Received:	11/05/2025 11:09
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper	0.11	mg/L	0.05	11/06/2025	1.3	EPA 200.8	7440-50-8
Lead	Not detected	mg/L	0.001	11/06/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: MIDLAND COUNTY HEALTH DEPT  
220 WEST ELLSWORTH ST  
MIDLAND MI 48640

**Sample ID:** LL92759  
**Work Order:** 51100255\_07

System Name/Owner:	HEAVENS ELECT CHILDCARE CENTER	WSSN/Pool ID:	
Collection Address:	3305 RIDGECREST DRIVE,MIDLAND	Source:	Single Family Dwelling
Collected By:	BOB WOLFE, RS	Site Code:	FILTER FIRST TESTING
Township/Well#/Section:	CITY OF MIDLAND//	Collector:	Other
County:	Midland	Date Collected:	11/04/2025 09:32
Sample Point:	HE-IR2-CF #7	Date Received:	11/05/2025 11:09
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper	Not detected	mg/L	0.05	11/06/2025	1.3	EPA 200.8	7440-50-8
Lead	Not detected	mg/L	0.001	11/06/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: MIDLAND COUNTY HEALTH DEPT  
220 WEST ELLSWORTH ST  
MIDLAND MI 48642

**Sample ID: LL92755**  
**Work Order: 51100255\_03**

System Name/Owner:	HEAVENS ELECT CHILDCARE CENTER	WSSN/Pool ID:	
Collection Address:	3305 RIDGECREST DRIVE,MIDLAND	Source:	Single Family Dwelling
Collected By:	BOB WOLFE, RS	Site Code:	FILTER FIRST TESTING
Township/Well#/Section:	CITY OF MIDLAND//	Collector:	Other
County:	Midland	Date Collected:	11/04/2025 09:08
Sample Point:	HE-KIT1-KF #3	Date Received:	11/05/2025 11:09
Water System:	Untreated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Copper	Not detected	mg/L	0.05	11/06/2025	1.3	EPA 200.8	7440-50-8
Lead	Not detected	mg/L	0.001	11/06/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Midland County Health Dept.  
220 West Ellsworth  
Midland, MI 48640-5194  
989 832-6679**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane