DEPARTMENT OF PUBLIC HEALTH

Fred Yanoski, MPH
Director/Health Officer

Phone (989) 832-6380
Fax (989) 832-6628

October 29, 2026

Heavens Elect Little People
3305 Ridgecrest Dr.
Midland, MI 48642

RE: Child Care Center Filter First Water Sampling results

Dear Heavens Elect staff,

Please find the attached results for faucet fixtures sampled. All faucets sampled "NOT DETECTED" for Lead analysis, except Kitchen Main Sink (HE-KIT1-KF). The Kitchen faucet tested at .002 mg/L ,which is still considered safe under the drinking water standards (less than 12 ppb (.12 mg/L)). Even though, a filter is provided on the faucet the filtering media is not longer effective and requires changing at an increased frequency or a larger filter should be considered. The EPA's goal is to have all drinking water lead free.

How Lead Gets Into Tap Water
Corrosion: Lead rarely occurs naturally in the water source itself. Instead, it enters water through the corrosion of older lead service lines, lead-soldered copper pipes, or brass/chrome-plated brass faucets.
Stagnation: Water sitting in contact with lead-containing pipes for long periods (such as overnight) accumulates higher concentrations.

Should you have any questions about interpretation contact us (989) 832-6380.

Sincerely,

Robert Wolfe

Robert Wolfe, R.S.
Environmental Health Sanitarian
bwolfe@co.midland.mi.us

EGLE

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01774

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01774-01

Collected By:	BOB WOLFE, RS		
Date Collected:	10/20/26 08:40	**Date Received:**	10/21/26 12:52
PWSID: MI0004370	**Facility ID:** SW-L		
Business/Homeowner:	HEAVEN'S ELECT LITTLE PEOPLE		
Collection Address:	3305 RIDGECREST DR MIDLAND, MI 48642		
County:	56-Midland		
Township:	*** Not Provided ***	**Section:**	*** Not Provided ***
Source ID:	*** Not Provided ***	**Site Code:**	FILTER FIRST TESTING
Sample Point:	6-Other	**Description:**	1 HE-SA-CF
Sample Type:	0-Routine Monitoring		

See next page for your analytical results

The test results in this report were produced at the EGLE Drinking Water Laboratory, 3350 N Martin Luther King Jr Blvd, Lansing, Michigan 48906, by authority of PA 368 of 1978 as amended, using methods approved by the United States Environmental Protection Agency under Drinking Water Certification No. MI00003 and in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed here.

Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640
Phone: 989 832-6679

RECEIVED
OCT 27 2026
BY:_____

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01774

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01774-01

TESTING INFORMATION						REGULATORY INFORMATION		
Analysis **Analyte** Result	Units	RL	Analyzed Date By	Qualifiers		MCL / AL	Method	CAS #
Lead								
Lead ND	mg/L	0.001	10/22/26 CL			0.012	EPA 200.8	7439-92-1

Definitions

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
ND: Not detected at or above the reporting limit (RL)
CAS: Chemical Abstract Service
CFU: Colony Forming Unit
mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number
NA: Not Applicable

Document Disclosures

If you need an EGLE document in an alternate format, contact EGLE-Accessibility@Michigan.gov or call 800-662-9278. EGLE does not discriminate on the basis of race, sex, religion, age, national origin, color, marital status, disability, political beliefs, height, weight, genetic information, or sexual orientation in the administration of any of its programs or activities, and prohibits intimidation and retaliation, as required by applicable laws and regulations. Questions or concerns should be directed to the Nondiscrimination Compliance Coordinator at EGLE-NondiscriminationCC@Michigan.gov or 517-249-0906. EGLE forms and their contents may be subject to the Freedom of Information Act and released to the public.

EGLE

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01775

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01775-01

Collected By:	BOB WOLFE, RS		
Date Collected:	10/20/26 08:40	**Date Received:**	10/21/26 12:52
PWSID: MI0004370	**Facility ID:** SW-L		
Business/Homeowner:	HEAVEN'S ELECT LITTLE PEOPLE		
Collection Address:	3305 RIDGECREST DR MIDLAND, MI 48642		
County:	56-Midland		
Township:	*** Not Provided ***	**Section:**	*** Not Provided ***
Source ID:	*** Not Provided ***	**Site Code:**	FILTER FIRST TESTING
Sample Point:	6-Other	**Description:**	2 HE-SL-TL
Sample Type:	0-Routine Monitoring		

See next page for your analytical results

The test results in this report were produced at the EGLE Drinking Water Laboratory, 3350 N Martin Luther King Jr Blvd, Lansing, Michigan 48906, by authority of PA 368 of 1978 as amended, using methods approved by the United States Environmental Protection Agency under Drinking Water Certification No. MI00003 and in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed here.

Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640
Phone: 989 832-6679

RECEIVED
OCT 27 2026
BY:_____

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01775

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01775-01

TESTING INFORMATION					REGULATORY INFORMATION		
Analysis / **Analyte** / Result	Units	RL	Analyzed Date By	Qualifiers	MCL / AL	Method	CAS #
Lead							
Lead							
ND	mg/L	0.001	10/22/26 CL		0.012	EPA 200.8	7439-92-1

Definitions

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
ND: Not detected at or above the reporting limit (RL)
CAS: Chemical Abstract Service
CFU: Colony Forming Unit
mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number
NA: Not Applicable

Document Disclosures

If you need an EGLE document in an alternate format, contact EGLE-Accessibility@Michigan.gov or call 800-662-9278. EGLE does not discriminate on the basis of race, sex, religion, age, national origin, color, marital status, disability, political beliefs, height, weight, genetic information, or sexual orientation in the administration of any of its programs or activities, and prohibits intimidation and retaliation, as required by applicable laws and regulations. Questions or concerns should be directed to the Nondiscrimination Compliance Coordinator at EGLE-NondiscriminationCC@Michigan.gov or 517-249-0906. EGLE forms and their contents may be subject to the Freedom of Information Act and released to the public.

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01772

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01772-01

Collected By:	BOB WOLFE, RS		
Date Collected:	10/20/26 08:40	**Date Received:**	10/21/26 12:52
PWSID: MI0004370	**Facility ID:** SW-L		
Business/Homeowner:	HEAVEN'S ELECT LITTLE PEOPLE		
Collection Address:	3305 RIDGECREST DR MIDLAND, MI 48642		
County:	56-Midland		
Township:	*** Not Provided ***	**Section:**	*** Not Provided ***
Source ID:	*** Not Provided ***	**Site Code:**	FILTER FIRST TESTING
Sample Point:	6-Other	**Description:**	3 HE-KIT1-KF
Sample Type:	0-Routine Monitoring		

See next page for your analytical results

The test results in this report were produced at the EGLE Drinking Water Laboratory, 3350 N Martin Luther King Jr Blvd, Lansing, Michigan 48906, by authority of PA 368 of 1978 as amended, using methods approved by the United States Environmental Protection Agency under Drinking Water Certification No. MI00003 and in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed here.

Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640
Phone: 989 832-6679

RECEIVED
OCT 27 2026
BY:_____

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01772

Report To: MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01772-01

TESTING INFORMATION						REGULATORY INFORMATION		
Analysis **Analyte** Result	Units	RL	Analyzed Date By	Qualifiers		MCL / AL	Method	CAS #
Lead								
Lead 0.002	mg/L	0.001	10/22/26 CL			0.012	EPA 200.8	7439-92-1

Definitions

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
ND: Not detected at or above the reporting limit (RL)
CAS: Chemical Abstract Service
CFU: Colony Forming Unit
mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number
NA: Not Applicable

Document Disclosures

If you need an EGLE document in an alternate format, contact EGLE-Accessibility@Michigan.gov or call 800-662-9278. EGLE does not discriminate on the basis of race, sex, religion, age, national origin, color, marital status, disability, political beliefs, height, weight, genetic information, or sexual orientation in the administration of any of its programs or activities, and prohibits intimidation and retaliation, as required by applicable laws and regulations. Questions or concerns should be directed to the Nondiscrimination Compliance Coordinator at EGLE-NondiscriminationCC@Michigan.gov or 517-249-0906. EGLE forms and their contents may be subject to the Freedom of Information Act and released to the public.

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01770

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01770-01

Collected By:	BOB WOLFE, RS		
Date Collected:	10/20/26 08:40	**Date Received:**	10/21/26 12:51
PWSID: MI0004370	**Facility ID:** SW-L		
Business/Homeowner:	HEAVEN'S ELECT LITTLE PEOPLE		
Collection Address:	3305 RIDGECREST DR MIDLAND, MI 48642		
County:	56-Midland		
Township:	*** Not Provided ***	**Section:**	*** Not Provided ***
Source ID:	*** Not Provided ***	**Site Code:**	FILTER FIRST TESTING
Sample Point:	6-Other	**Description:**	4 HE-LR-DF
Sample Type:	0-Routine Monitoring		

See next page for your analytical results

The test results in this report were produced at the EGLE Drinking Water Laboratory, 3350 N Martin Luther King Jr Blvd, Lansing, Michigan 48906, by authority of PA 368 of 1978 as amended, using methods approved by the United States Environmental Protection Agency under Drinking Water Certification No. MI00003 and in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed here.

Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640
Phone: 989 832-6679

RECEIVED
OCT 27 2026
BY:_____

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01770

Report To: MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01770-01

TESTING INFORMATION					REGULATORY INFORMATION		
Analysis / **Analyte** / Result	Units	RL	Analyzed Date By	Qualifiers	MCL / AL	Method	CAS #
Lead							
Lead							
ND	mg/L	0.001	10/22/26 CL		0.012	EPA 200.8	7439-92-1

Definitions

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
ND: Not detected at or above the reporting limit (RL)
CAS: Chemical Abstract Service
CFU: Colony Forming Unit
mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number
NA: Not Applicable

Document Disclosures

If you need an EGLE document in an alternate format, contact EGLE-Accessibility@Michigan.gov or call 800-662-9278. EGLE does not discriminate on the basis of race, sex, religion, age, national origin, color, marital status, disability, political beliefs, height, weight, genetic information, or sexual orientation in the administration of any of its programs or activities, and prohibits intimidation and retaliation, as required by applicable laws and regulations. Questions or concerns should be directed to the Nondiscrimination Compliance Coordinator at EGLE-NondiscriminationCC@Michigan.gov or 517-249-0906. EGLE forms and their contents may be subject to the Freedom of Information Act and released to the public.

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01773

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01773-01

Collected By:	BOB WOLFE, RS		
Date Collected:	10/20/26 08:40	**Date Received:**	10/21/26 12:52
PWSID: MI0004370	**Facility ID:** SW-L		
Business/Homeowner:	HEAVEN'S ELECT LITTLE PEOPLE		
Collection Address:	3305 RIDGECREST DR MIDLAND, MI 48642		
County:	56-Midland		
Township:	*** Not Provided ***	**Section:**	*** Not Provided ***
Source ID:	*** Not Provided ***	**Site Code:**	FILTER FIRST TESTING
Sample Point:	6-Other	**Description:**	5 HE K3H DF
Sample Type:	0-Routine Monitoring		

See next page for your analytical results

The test results in this report were produced at the EGLE Drinking Water Laboratory, 3350 N Martin Luther King Jr Blvd, Lansing, Michigan 48906, by authority of PA 368 of 1978 as amended, using methods approved by the United States Environmental Protection Agency under Drinking Water Certification No. MI00003 and in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed here.

Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640
Phone: 989 832-6679

RECEIVED
OCT 27 2026
BY:_____

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01773

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01773-01

TESTING INFORMATION						REGULATORY INFORMATION		
Analysis **Analyte** Result	Units	RL	Analyzed Date By	Qualifiers		MCL / AL	Method	CAS #
Lead								
Lead ND	mg/L	0.001	10/22/26 CL			0.012	EPA 200.8	7439-92-1

Definitions

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
ND: Not detected at or above the reporting limit (RL)
CAS: Chemical Abstract Service
CFU: Colony Forming Unit
mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number
NA: Not Applicable

Document Disclosures

If you need an EGLE document in an alternate format, contact EGLE-Accessibility@Michigan.gov or call 800-662-9278. EGLE does not discriminate on the basis of race, sex, religion, age, national origin, color, marital status, disability, political beliefs, height, weight, genetic information, or sexual orientation in the administration of any of its programs or activities, and prohibits intimidation and retaliation, as required by applicable laws and regulations. Questions or concerns should be directed to the Nondiscrimination Compliance Coordinator at EGLE-NondiscriminationCC@Michigan.gov or 517-249-0906. EGLE forms and their contents may be subject to the Freedom of Information Act and released to the public.

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01771

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01771-01

Collected By:	BOB WOLFE, RS		
Date Collected:	10/20/26 08:50	**Date Received:**	10/21/26 12:52
PWSID: MI0004370	**Facility ID:** SW-L		
Business/Homeowner:	HEAVEN'S ELECT LITTLE PEOPLE		
Collection Address:	3305 RIDGECREST DR MIDLAND, MI 48642		
County:	56-Midland		
Township:	*** Not Provided ***	**Section:**	*** Not Provided ***
Source ID:	*** Not Provided ***	**Site Code:**	FILTER FIRST TESTING
Sample Point:	6-Other	**Description:**	6 HE-IR-CF
Sample Type:	0-Routine Monitoring		

See next page for your analytical results

The test results in this report were produced at the EGLE Drinking Water Laboratory, 3350 N Martin Luther King Jr Blvd, Lansing, Michigan 48906, by authority of PA 368 of 1978 as amended, using methods approved by the United States Environmental Protection Agency under Drinking Water Certification No. MI00003 and in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed here.

Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640
Phone: 989 832-6679

RECEIVED
OCT 27 2026
BY:_____

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01771

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01771-01

TESTING INFORMATION						REGULATORY INFORMATION		
Analysis / **Analyte** / Result	Units	RL	Analyzed Date	By	Qualifiers	MCL / AL	Method	CAS #
Lead								
Lead								
ND	mg/L	0.001	10/22/26	CL		0.012	EPA 200.8	7439-92-1

Definitions

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
ND: Not detected at or above the reporting limit (RL)
CAS: Chemical Abstract Service
CFU: Colony Forming Unit
mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number
NA: Not Applicable

Document Disclosures

If you need an EGLE document in an alternate format, contact EGLE-Accessibility@Michigan.gov or call 800-662-9278. EGLE does not discriminate on the basis of race, sex, religion, age, national origin, color, marital status, disability, political beliefs, height, weight, genetic information, or sexual orientation in the administration of any of its programs or activities, and prohibits intimidation and retaliation, as required by applicable laws and regulations. Questions or concerns should be directed to the Nondiscrimination Compliance Coordinator at EGLE-NondiscriminationCC@Michigan.gov or 517-249-0906. EGLE forms and their contents may be subject to the Freedom of Information Act and released to the public.

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01769

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01769-01

Collected By:	BOB WOLFE, RS		
Date Collected:	10/20/26 08:55	**Date Received:**	10/21/26 12:51
PWSID: MI0004370	**Facility ID:** SW-L		
Business/Homeowner:	HEAVEN'S ELECT LITTLE PEOPLE		
Collection Address:	3305 RIDGECREST DR MIDLAND, MI 48642		
County:	56-Midland		
Township:	*** Not Provided ***	**Section:**	*** Not Provided ***
Source ID:	*** Not Provided ***	**Site Code:**	FILTER FIRST TESTING
Sample Point:	6-Other	**Description:**	7 HE-IR2-CF
Sample Type:	0-Routine Monitoring		

See next page for your analytical results

The test results in this report were produced at the EGLE Drinking Water Laboratory, 3350 N Martin Luther King Jr Blvd, Lansing, Michigan 48906, by authority of PA 368 of 1978 as amended, using methods approved by the United States Environmental Protection Agency under Drinking Water Certification No. MI00003 and in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed here.

Midland County Health Dept.
220 West Ellsworth
Midland, MI 48640
Phone: 989 832-6679

RECEIVED
OCT 27 2026
BY:_____

MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
Remediation and Redevelopment Division - Laboratory Services

Official Drinking Water Laboratory Report

Account: 0007224
Work Order: 26J01769

Report To: **MIDLAND COUNTY DEPARTMENT OF PUBLIC HEALTH**
220 E ELLSWORTH
MIDLAND, MI 48640

Sample ID: 26J01769-01

TESTING INFORMATION					REGULATORY INFORMATION		
Analysis / **Analyte** / Result	Units	RL	Analyzed Date By	Qualifiers	MCL / AL	Method	CAS #
Lead							
Lead							
ND	mg/L	0.001	10/22/26 CL		0.012	EPA 200.8	7439-92-1

Definitions

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
ND: Not detected at or above the reporting limit (RL)
CAS: Chemical Abstract Service
CFU: Colony Forming Unit
mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number
NA: Not Applicable

Document Disclosures

If you need an EGLE document in an alternate format, contact EGLE-Accessibility@Michigan.gov or call 800-662-9278. EGLE does not discriminate on the basis of race, sex, religion, age, national origin, color, marital status, disability, political beliefs, height, weight, genetic information, or sexual orientation in the administration of any of its programs or activities, and prohibits intimidation and retaliation, as required by applicable laws and regulations. Questions or concerns should be directed to the Nondiscrimination Compliance Coordinator at EGLE-NondiscriminationCC@Michigan.gov or 517-249-0906. EGLE forms and their contents may be subject to the Freedom of Information Act and released to the public.